



DEVELOPER IS TO FURNISH AND INSTALL ALL GUARD POSTS AND CONCRETE AS REQUIRED ON CORED SITE PLAN.

QUANTITY AND ARRANGEMENT OF GUARD POSTS ARE TO BE DETERMINED BY LOCATION OF CORED PAD MOUNTED TRANSFORMER IN RELATION TO PARKING AREAS AND DRIVE AREAS.

GUARD POSTS ARE TO BE RIGID SCH. STEEL, 5" I.D. X 8'-0" LONG, CONCRETE FILLED AND SET IN AN 18" DIA. CONCRETE FILLED HOLE.

CORED

SCALE: NTS

RWS

UNDERGROUND EXTENSION STANDARD
FOR GUARD POSTS
DETAILS AND ARRANGEMENTS

DATE: 6/15/00

STANDARD
NUMBER

CORED482.DWG
A-PMT-PWGP