

Rev. No.	Date	By	Appd.	Description
0	7/31/00	RWS	MEB	Original Drawing.
1	1/23/01	MED	MEB	Updated border & added ground rod.
2	2/7/01	MED	MEB	Updated sheet 1 and added sheets 2 & 3.

- Customer calls Tennessee One Call before performing trenching, 1-800-351-1111. Please note that the Tennessee One Call system requires a 3 day wait, after a request, to allow utilities time to mark their infrastructure.
- Customer performs trenching and installation of conduit, tape, and pedestals pursuant with the attached construction specifications, see drawing 484.S03
- Customer calls the Electric Department at 425-1803 for an inspection of riser conduit installation on the overhead electric pole.
- Customer applies for permanent service at the Utility Business Office. The Utility Business Office is located at the Municipal Building at the corner of the Oak Ridge Turnpike and Tulane Avenue. A connection fee, and possibly a deposit, will be collected during the application for permanent service.
- Questions that arise during construction regarding requirements of the NEC should be directed to Codes Enforcement Division of the Community Development Department. After completing the meter base work, the Customer calls Codes Enforcement at 425-3532 for an inspection of the meter base. Codes Enforcement will check the installation for compliance with the National Electric Code (NEC). If all is in order, UBO will notify the Electric Department that the customer is ready for service.
- The Customer will pull the service conductors, and make terminations at the meter. CORED will make terminations on the transformer, and install the meter. The customer, or his representative, must be present when the meter is installed to verify their main breaker is open. The customer is responsible for closing his main breaker after the meter is installed. If the customer has any questions regarding the schedule for making terminations, they may call 425-1861, or call 425-1803 and ask for Operations.

<b>CORED</b> SCALE: NTS RWS	Three/Single Phase Commercial Underground Secondary Service Extensions Customer Requirements (Single Phase Shown) www.ored.org (Click on Contractor Info.)	DATE: 7/31/00
		<b>STANDARD NUMBER</b> 484.S01.R02